

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-10529  
Name of Facility: M.A. Milam Elem. PLC  
Address: 6020 W 16 Avenue  
City, Zip: Hialeah 33012

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Public School  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Anna Hernandez Phone: 305-822-0301

**Inspection Information**

Purpose: Reinspection  
Inspection Date: 6/1/2017

Begin Time: 10:00 AM  
End Time: 10:45 AM

**Additional Information**

FEMALES ..... 271  
MALES ..... 301

CENSUS ..... 572

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	X 23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
X 6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

**General Comments**

Critical violations have been corrected. Satisfactory inspection

Email Address(es): louloy@dadeschools.net;  
annamhernandez@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #6. Lighting/Foot-Candles

Replace burnt light bulbs in room 905, 907, 902, in bathroom 1107

Increase lighting in bathrooms of rooms 907, 903, 901

CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Violation #23. Infestation/Control

Repair screens at window in restroom 604

CODE REFERENCE: Infestation/Control 64E-13.004(10). Effective measures shall be used to prevent harborage, propagation, or infestations of rodents and all insects.

Inspection Conducted By: Naissa Julien (84600)  
Inspector Contact Number: Work: (305) 623-3500 ex. 24222  
Print Client Name:  
Date: 6/1/2017

Inspector Signature:

Handwritten signature of Naissa Julien.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-07928  
Name of Facility: M.A. Milam Middle Learning CTR.  
Address: 6020 W 16 Avenue  
City, Zip: Hialeah 33012

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Public School  
Owner: M-DCSB Food and Nutrition  
Person In Charge: Anna Hernandez Phone: 305-822-0301

**Inspection Information**

Purpose: Routine  
Inspection Date: 4/17/2017

Begin Time: 11:20 AM  
End Time: 12:30 PM

**Additional Information**

FEMALES ..... 271  
MALES ..... 301

CENSUS ..... 572

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION	<input checked="" type="checkbox"/> 11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
<input checked="" type="checkbox"/> 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
<input checked="" type="checkbox"/> 10. Provided/Accessible	21. Sewage Disposal	

**General Comments**

No General Comments Available

Email Address(es): louloy@dadeschools.net;  
annahernandez@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

**Violation #5. Maintenance & Repair**

Provide missing ceiling tile above drinking water fountain next to equipment room 124  
Clean vent in bathroom of room 147 to remove dust accumulation  
Remove peeling paint off wall next to room 210, on wall by room 131 and all other applicable  
Replace stained ceiling tiles in room 215, 221 and all other applicable  
Replace burnt light bulbs in room 124 2D, in room 215 and all other applicable

CODE REFERENCE: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

**Violation #10. Provided/Accessible**

Secure faucet at handwashing sink in bathroom of 202A  
CODE REFERENCE: Provided/Accessible 64E-13.004(6). Every school plant shall be provided with toilet and hand washing facilities for all occupants. These facilities shall be located for convenient student access and faculty supervision and kept clean and in good repair. Faculty and staff facilities shall be provided in separate rooms from student facilities.

**Violation #11. Cleanliness & Repair**

Eliminate the use of deodorizers in restroom of room 202A  
CODE REFERENCE: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.

Inspection Conducted By: Naissa Julien (84600)  
Inspector Contact Number: Work: (305) 623-3500 ex. 24222  
Print Client Name:  
Date: 4/17/2017

Inspector Signature:

Handwritten signature of Naissa Julien.

Client Signature:

Handwritten signature of Ama Hernandez.